

### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong, Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE

: Testing of Valve

**OUR REFERENCE** 

J13816A-1

DESCRIPTION OF SAMPLE:

20mm Stainless steel globe valve; pressure rating PN16;

female screwed ends to BS21.

SAMPLE SUBMITTED BY

Waterfront Fluid Controls Limited Unit 6, Elderpark Workspace,

100 Elderpark Street, Glasgow, U. K.

**BRAND** 

: Waterfront

MANUFACTURER

Waterfront Fluid Controls Limited

**ORIGIN** 

U.K.

**SERIES** 

511

**BODY MARKINGS** 

 $\sum$ 

~~**~** 

200 CE8M

TEST REQUIRED

BS5154: 1991; BSEN12288: 2003; BSEN12266-1: 2003

(There is no British Standard for globe valve made of stainless steel. To show the hydraulic strength of the valve sample, the test procedures laid down in BS5154, BSEN12266-1; 2003 and BSEN12288; 2003 were

adopted for reference.)

PERIOD OF TESTS

3<sup>rd</sup> to 20<sup>th</sup> August 2009

RESULTS: - (apply only to sample tested)

1. DIMENSIONS (in millimetres)

	Sample
Nominal size	20
Height of valve, from top to bottom, valve fully open	132
Diameter of handwheel	80.2
Face to face dimension	66.1
Minimum stem diameter	8.6
Minimum body thickness	3.2

Note: the female threads at the water inlet and water outlet comply with ISO7-1 and BS21.

#### 2. HYDRAULIC PRESSURE TEST (BSEN12288, Clause 5.1 & 5.3; BSEN12266-1; 2003; BS5154, Clause 11)

	Nominal	` '			Seat tightness test (1.1 PN)			
	pressure PN (bar)	Test pressure (bar)	pressure Duration Remark		Test pressure (bar) Duration (s)		Remark	
Sample	16	24	15	Pass	18	15	Pass	
BSEN12288's Requirement	16	24	15	/	18	15	/	
BS5154's Requirement	16	24	15	/	18	15	/	

Note: no leakage was detected during the above test.



#### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street. Fo Tan, Shatin, N.T., Hong Kong, Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

### OUR REFERENCE NO.J13816A-1 (P.2)

#### 3. CHEMICAL COMPOSITIONS

	Element compositions (%)								
Component	С	Si	Mn	n Ni Mo Cr S P	Designation				
Body, bonnet, Disc & Stem	0.029	0.33	1.62	11.0	2.5	17.7	0.01	0.01	grade 316S31 of BS970: Part 1 and grade X5CrNiMo17- 12-2 (1.4401) of BSEN10088

4. SUMMARY OF RESULTS (apply only to the sample tested)

**Dimensions** 

- Satisfactory

Hydraulic pressure test - Satisfactory

Chemical compositions - Satisfactory; the chemical composition test results for the valve body,

bonnet, stem and disc comply with BS970 part 1 grade 316S31 and grade

X5CrNiMo17-12-2 (1.4401) of BSEN10088.

Remark: the internal water passage surface of the sample does not have any metallic coating.

\_\_Authorized signature : \_\_

Nutek Systems is a testing agency, spproved by the Water Authority and Gevernment Supplies Department, for testing water supply fittings.

Samson W.K. Yiu



### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE

: Testing of Valve

**OUR REFERENCE** 

J13816B-1

DESCRIPTION OF SAMPLE:

25mm Stainless steel globe valve; pressure rating PN16;

female screwed ends to BS21.

SAMPLE SUBMITTED BY

Waterfront Fluid Controls Limited Unit 6, Elderpark Workspace,

100 Elderpark Street, Glasgow, U. K.

**BRAND** 

: Waterfront

MANUFACTURER

Waterfront Fluid Controls Limited

**ORIGIN** 

: U.K.

**SERIES** 

511

**BODY MARKINGS** 

 $\sum$ 

200 CF8M

TEST REQUIRED

: BS5154: 1991; BSEN12288: 2003; BSEN12266-1: 2003

(There is no British Standard for globe valve made of stainless steel. To show the hydraulic strength of the valve sample, the test procedures laid down in BS5154, BSEN12266-1; 2003 and BSEN12288: 2003 were

adopted for reference.)

PERIOD OF TESTS

3<sup>rd</sup> to 20<sup>th</sup> August 2009

RESULTS: - (apply only to sample tested)

1. DIMENSIONS (in millimetres)

Sample
25
149.7
80.3
76.3
8.6
3.35

Note: the female threads at the water inlet and water outlet comply with ISO7-1 and BS21.

### 2. HYDRAULIC PRESSURE TEST (BSEN12288, Clause 5.1 & 5.3; BSEN12266-1: 2003; BS5154, Clause 11)

	Nominal	Shell tightness test (1.5 PN)  Test pressure (bar)  Duration (s)  Remark		(1.5 PN)	Seat tightness test (1.1 PN)			
	pressure PN (bar)			Remark	Test pressure (bar)	Duration (s)	Remark	
Sample	16	24	15	Pass	18	15	Pass	
BSEN12288's Requirement	16	24	15	/	18	15	/	
BS5154's Requirement	16	24	15	/	18	15	/	

Note: no leakage was detected during the above test.



#### **TEST** REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street. Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

#### OUR REFERENCE NO.J13816B-1 (P.2)

#### 3. CHEMICAL COMPOSITIONS

_	Element compositions (%)								
Component	С	Si	Mn	Ni	Мо	Cr	S	P	Designation
Body, bonnet,	0.049	0.36	1.74	11.2	2.42	18.0	0.01	0.01	grade 316S31 of BS970: Part 1 and
Disc & Stem	0.049	0.30	1./4	11.4	4.44	16.0	0.01	0.01	grade X5CrNiMo17- 12-2 (1.4401) of BSEN10088

4. SUMMARY OF RESULTS (apply only to the sample tested)

**Dimensions** 

- Satisfactory

Hydraulic pressure test - Satisfactory

Chemical compositions -- Satisfactory; the chemical composition test results for the valve body,

bonnet, stem and disc comply with BS970 part 1 grade 316S31 and grade

X5CrNiMo17-12-2 (1.4401) of BSEN10088.

Remark: the internal water passage surface of the sample does not have any metallic coating.

Authorized signature:

Samson W.K. Yiu

Nutek Systems is a testing agency, approved by the Water Authority and Government Supplies Department, for

testing water supply fittings.



### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE : Testing of Valve

OUR REFERENCE : J13816C-1

DESCRIPTION OF SAMPLE : 32mm Stainless steel globe valve; pressure rating PN16;

female screwed ends to BS21.

SAMPLE SUBMITTED BY : Waterfront Fluid Controls Limited

Unit 6, Elderpark Workspace,

100 Elderpark Street, Glasgow, U. K.

BRAND : Waterfront

MANUFACTURER : Waterfront Fluid Controls Limited

ORIGIN : U. K.

SERIES : 511

BODY MARKINGS : \(\sum\_{\infty}\)

1-¼ 200 CF8M

TEST REQUIRED : BS5154 : 1991; BSEN12288: 2003; BSEN12266-1: 2003

(There is no British Standard for globe valve made of stainless steel. To show the hydraulic strength of the valve sample, the test procedures laid down in BS5154, BSEN12266-1; 2003 and BSEN12288: 2003 were

adopted for reference.)

PERIOD OF TESTS : 3<sup>rd</sup> to 20<sup>th</sup> August 2009

RESULTS: - (apply only to sample tested)

1. DIMENSIONS (in millimetres)

	Sample
Nominal size	32
Height of valve, from top to bottom, valve fully open	180.5
Diameter of handwheel	89.3
Face to face dimension	86.5
Minimum stem diameter	10.6
Minimum body thickness	3.6

Note: the female threads at the water inlet and water outlet comply with ISO7-1 and BS21.

### 2. HYDRAULIC PRESSURE TEST (BSEN12288, Clause 5.1 & 5.3; BSEN12266-1: 2003; BS5154, Clause 11)

	Nominal				Seat tightness test (1.1 PN)			
	pressure PN (bar)	Test pressure (bar) Duration (s)		Remark	Test pressure (bar)	Duration (s)	Remark	
Sample	16	24	15	Pass	18	15	Pass	
BSEN12288's Requirement	16	24	15	/	18	15	/	
BS5154's Requirement	16	24	15	/	18	15	/	

Note: no leakage was detected during the above test.



## TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

#### OUR REFERENCE NO.J13816C-1 (P.2)

#### 3. CHEMICAL COMPOSITIONS

		Element compositions (%)							
Component	C	Si	Mn	Ni	Mo	Cr	S	Р	Designation
Body, bonnet, Disc & Stem	0.049	0.45	1.59	11.7	2.40	17.9	0.01	0.01	grade 316S31 of BS970: Part 1 and grade X5CrNiMo17- 12-2 (1.4401) of BSEN10088

4. SUMMARY OF RESULTS (apply only to the sample tested)

**Dimensions** 

- Satisfactory

Hydraulic pressure test - Satisfactory

Chemical compositions -- Satisfactory; the chemical composition test results for the valve body,

bonnet, stem and disc comply with BS970 part 1 grade 316S31 and grade

X5CrNiMo17-12-2 (1.4401) of BSEN10088.

Remark: the internal water passage surface of the sample does not have any metallic coating.

Authorized signature:

Nutek Systems is a testing agency, approved by the Water Authority and Government Supplies Department, for

testing water supply fittings.

Samson W.K. Yiu



### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE : Testing of Valve

OUR REFERENCE : J13816D-1

DESCRIPTION OF SAMPLE: 40mm Stainless steel globe valve; pressure rating PN16;

female screwed ends to BS21.

SAMPLE SUBMITTED BY : Waterfront Fluid Controls Limited

Unit 6, Elderpark Workspace,

100 Elderpark Street, Glasgow, U. K.

BRAND : Waterfront

MANUFACTURER : Waterfront Fluid Controls Limited

ORIGIN : U. K.

SERIES : 511

BODY MARKINGS : ∑⇒

1-½ 200 CF8M

TEST REQUIRED : BS5154 : 1991; BSEN12288: 2003; BSEN12266-1: 2003

(There is no British Standard for globe valve made of stainless steel. To show the hydraulic strength of the valve sample, the test procedures laid down in BS5154, BSEN12266-1; 2003 and BSEN12288: 2003 were

adopted for reference.)

PERIOD OF TESTS : 3<sup>rd</sup> to 20<sup>th</sup> August 2009

RESULTS: - (apply only to sample tested)

1. DIMENSIONS (in millimetres)

Sample
40
171.5
89.2
94.6
10.6
4.1

Note: the female threads at the water inlet and water outlet comply with ISO7-1 and BS21.

### 2. HYDRAULIC PRESSURE TEST (BSEN12288, Clause 5.1 & 5.3; BSEN12266-1: 2003; BS5154, Clause 11)

	Nominal	Shell tightness test (1.5 PN			Seat tightness test (1.1 PN)			
	pressure PN (bar)	PN ressure Duration Rep		Remark	Test pressure (bar)	Duration (s)	Remark	
Sample	16	24	15	Pass	18	15	Pass	
BSEN12288's Requirement	16	24	15	/	18	15	/	
BS5154's Requirement	16	24	15	/	18	15	/	

Note: no leakage was detected during the above test.



### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

#### OUR REFERENCE NO.J13816D-1 (P.2)

#### 3. CHEMICAL COMPOSITIONS

Component	С	Si	Mn	Ni	Mo	Cr	S	Р	Designation
Body, bonnet, Disc & Stem	0.038	0.22	1.77	11.6	2.43	18.2	0.01	0.01	grade 316S31 of BS970: Part 1 and grade X5CrNiMo17- 12-2 (1.4401) of BSEN10088

4. SUMMARY OF RESULTS (apply only to the sample tested)

Dimensions

- Satisfactory

Hydraulic pressure test - Satisfactory

Chemical compositions -- Satisfactory; the chemical composition test results for the valve body,

bonnet, stem and disc comply with BS970 part 1 grade 316S31 and grade

X5CrNiMo17-12-2 (1.4401) of BSEN10088.

Remark: the internal water passage surface of the sample does not have any metallic coating.

Date: 13 Selfuber

\_Authorized signature:

Nutek Systems is a testing agency, approved by the Water Authority and Government Supplies Department, for

testing water supply fittings.

Samson W.K. Yiu



### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE : Testing of Valve

OUR REFERENCE : J13816E-1

DESCRIPTION OF SAMPLE: 50mm Stainless steel globe valve; pressure rating PN16;

female screwed ends to BS21.

SAMPLE SUBMITTED BY : Waterfront Fluid Controls Limited

Unit 6, Elderpark Workspace,

100 Elderpark Street, Glasgow, U. K.

BRAND : Waterfront

MANUFACTURER : Waterfront Fluid Controls Limited

ORIGIN : U. K.

SERIES : 511

BODY MARKINGS : ∑⇒⇒

200 CF8M

TEST REQUIRED : BS5154 : 1991; BSEN12288: 2003; BSEN12266-1: 2003

(There is no British Standard for globe valve made of stainless steel. To show the hydraulic strength of the valve sample, the test procedures laid down in BS5154, BSEN12266-1; 2003 and BSEN12288: 2003 were

adopted for reference.)

PERIOD OF TESTS : 3<sup>rd</sup> to 20<sup>th</sup> August 2009

RESULTS: - (apply only to sample tested)

1. DIMENSIONS (in millimetres)

	Sample
Nominal size	50
Height of valve, from top to bottom, valve fully open	201.5
Diameter of handwheel	100.8
Face to face dimension	116.8
Minimum stem diameter	10.6
Minimum body thickness	5.1

Note: the female threads at the water inlet and water outlet comply with ISO7-1 and BS21.

### 2. HYDRAULIC PRESSURE TEST (BSEN12288, Clause 5.1 & 5.3; BSEN12266-1: 2003; BS5154, Clause 11)

	Nominal pressure PN (bar)	Shell tightness test		(1.5 PN)	Seat tightness test (1.1 PN)			
		Test pressure (bar)	Duration (s)	Remark	Test pressure (bar)	Duration (s)	Remark	
Sample	16	24	15	Pass	18	15	Pass	
BSEN12288's Requirement	16	24	15	/	18	15	/	
BS5154's Requirement	16	24	15	/	18	15	1	

Note: no leakage was detected during the above test.



#### TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street. Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

#### OUR REFERENCE NO.J13816E-1 (P.2)

#### 3. CHEMICAL COMPOSITIONS

	Element compositions (%)								
Component	С	Si	Mn	Ni	Мо	Cr	S	P	Designation
Body, bonnet, Disc & Stem	0.042	0.39	1.63	11.2	2.47	18.0	0.01	0.01	grade 316S31 of BS970: Part 1 and grade X5CrNiMo17- 12-2 (1.4401) of BSEN10088

4. SUMMARY OF RESULTS (apply only to the sample tested)

**Dimensions** 

- Satisfactory

Hydraulic pressure test - Satisfactory

Chemical compositions -- Satisfactory; the chemical composition test results for the valve body,

bonnet, stem and disc comply with BS970 part 1 grade 316S31 and grade

X5CrNiMo17-12-2 (1.4401) of BSEN10088.

Remark: the internal water passage surface of the sample does not have any metallic coating.

Nutek Systems is a testing agency, approved by the Water Authority and

\_Authorized signature:

Samson W.K. Yiu

Government Supplies Department,

testing water supply fittings.