

水 務 署 Water Supplies Department

香港灣仔告士打道七號入境事務大樓 Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞

wsdinfo@wsd.gov.hk

e-mail

電 話 2829 4367

圖文傳真 2824 0578

Telephone 2829 430

Facsimile

檔 號 (2) in WSD 3321/09 Pt.1 T/J(285)

30 December 2009

Waterfront Fluid Controls Ltd. Unit C, 19/F, Best-O-Best Commercial Centre, 32-36 Ferry Street, Kowloon, Hong Kong.

(Attn.: Mr. Kenny M. H. HO)

Dear Sirs

Approval of "Waterfront" Stainless Steel Globe Valves

Your letter ref. WL-091225 dated 23 December 2009 refers.

Having considered the test reports by the Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

Waterfront Fluid Controls Ltd.

Country of Origin:

U.K.

Brand:

Waterfront.

Details of Fittings:

20mm (¾"), 25mm (1"), 32mm (1¼"), 40mm (1½") and 50mm (2") Stainless steel of grade 316 globe valves (no internally applied metallic coating) to BS EN 12288; BS 5154 & BS EN 12266-1; female screwed

ends to BS 21; pressure rating PN16.

Model No.: Series 511.

Body Markings:

₩

XX 200 CF8M

(where XX denotes 34,1,114,114 or 2)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,

(CHIN Chu Sum)

for Water Authority