

NUTEK SYSTEMS, LTD. Unit B, 13/F., Universal 23-25 Shan Mei Street,

TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE : Testing of Valve

OUR REFERENCE : J13817-1

DESCRIPTION OF SAMPLE: Stainless steel check valve; pressure rating PN16; female screwed ends

to BS21; size: 20mm, 25mm, 32mm, 40mm and 50mm

SAMPLE SUBMITTED BY : Waterfront Fluid Controls Limited

Unit 6, Elderpark Workspace,

100 Elderpark Street, Glasgow, U. K.

BRAND : Waterfront

MANUFACTURER : Waterfront Fluid Controls Limited

ORIGIN : U. K.

SERIES : 614

BODY MARKINGS :

nominal size *

CF8M 200

W

(* The nominal size: 34, 1, 114, 11/2 and 2 respectively.)

TEST REQUIRED : BS5154 : 1991; BSEN12288: 2003; BSEN12266-1: 2003

(There is no British Standard for check valve made of stainless steel. To show the hydraulic strength of the valve sample, the test procedures laid down in BS5154, BSEN12266-1; 2003 and BSEN12288; 2003 were

adopted for reference.)

PERIOD OF TESTS : 3rd to 20th August 2009

RESULTS: - (apply only to sample tested)

1. DIMENSIONS (in millimetres)

| | Sample | | | | | | |
|------------------------|--------|------|-------|-------|-------|--|--|
| Nominal size | 20 | 25 | 32 | 40 | 50 | | |
| Face to face dimension | 80.6 | 90.1 | 105.0 | 120.1 | 139.4 | | |
| Minimum body thickness | 2.75 | 3.15 | 3.50 | 4.00 | 4.00 | | |

Note: the female threads at the water inlet and water outlet of each valve sample comply with ISO7-1 and BS21.

2. HYDRAULIC PRESSURE TEST (BSEN12288, Clause 5.1 & 5.3; BSEN12266-1: 2003; BS5154, Clause 11)

| | Nominal pressure PN (bar) | Shell tightness test (1.5 PN) | | | Seat tightness test (1.1 PN) | | | |
|---|---------------------------|-------------------------------|--------------|--------|------------------------------|--------------|--------|--|
| | | Test pressure (bar) | Duration (s) | Remark | Test pressure (bar) | Duration (s) | Remark | |
| Samples (20mm, 25mm, 32mm, 40mm & 50mm) | 16 | 24 | 15 | Pass | 18 | 15 | Pass | |
| BSEN12288's Requirement | 16 | 24 | 15 | / | 18 | 15 | 1 | |
| BS5154's Requirement | 16 | 24 | 15 | / | 18 | 15 | / | |

Note: no leakage was detected during the above test.

/....P.2



NUTEK SYSTEMS, LTD.

TEST REPORT

Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong. Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

OUR REFERENCE NO.J13817-1 (P.2)

3. CHEMICAL COMPOSITIONS

One piece of the valve samples was randomly selected and subjected to the chemical composition test; the results are tabulated below:

| | Element compositions (%) | | | | | | | | | |
|---|--------------------------|------|------|------|------|------|------|------|--|--|
| Component | С | Si | Mn | Ni | Mo | Cr | S | P | Designation | |
| Body, bonnet, disc & hinge pin | 0.035 | 0.32 | 1.69 | 11.1 | 2.42 | 18.1 | 0.01 | 0.01 | grade 316S31 of BS970: Part 1 and grade X5CrNiMo17- 12-2 (1.4401) of BSEN10088 | |

4. SUMMARY OF RESULTS (apply only to the sample tested)

Dimensions

- Satisfactory

Hydraulic pressure test – Satisfactory

Chemical compositions - Satisfactory; the chemical composition test results for the valve body,

bonnet, disc and hinge pin comply with BS970 part 1 grade 316S31 and grade

X5CrNiMo17-12-2 (1.4401) of BSEN10088.

Remark: the internal water passage surface of the sample does not have any metallic coating.

Date: 12th December 2009 Authorized signature:

Nutek Systems is a testing agency, approved by the Water Authority and Government Supplies Department, for testing water supply fittings.

Samson W.K. Yiu

(Director)