



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4367

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (2) in WSD 3321/09 Pl.1 T/J(284)

30 December 2009

Waterfront Fluid Controls Ltd.  
Unit C, 19/F, Best-O-Best Commercial Centre,  
32-36 Ferry Street,  
Kowloon, Hong Kong.

(Attn.: Mr. Kenny M. H. HO)

Dear Sirs

### Approval of "Waterfront" Stainless Steel Gate Valves

Your letter ref. WL-091224 dated 23 December 2009 refers.

Having considered the test reports by the Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Waterfront Fluid Controls Ltd.

**Country of Origin:** U.K.

**Brand:** Waterfront.

**Details of Fittings:** 15mm ( $\frac{1}{2}$ "), 20mm ( $\frac{3}{4}$ "), 25mm (1"), 32mm (1 $\frac{1}{4}$ "), 40mm (1 $\frac{1}{2}$ ") and 50mm (2") Stainless steel of grade 316 gate valves (no internally applied metallic coating) to BS EN 12288; BS 5154 & BS EN 12266-1; female screwed ends to BS 21; pressure rating PN16.  
Model No.: Series 213.  
Body Markings:



XX  
CF8M  
200

(where XX denotes  $\frac{1}{2}$ ,  $\frac{3}{4}$ , 1, 1 $\frac{1}{4}$ , 1 $\frac{1}{2}$  or 2)


This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,

---



(CHIN Chu Sum)  
for Water Authority