



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

檔號

Reference

2829 4367

圖文傳真

Facsimile

2824 0578

(2) in WSD 3321/11 Pt.1 T/J(281)

20 December 2011

Gate Way Valve & Fitting Ltd.
Flat A2, 4/F., Galaxy Factory Building,
25-27 Luk Hop Street, San Po Kong,
Kowloon, Hong Kong

(Attn.: Mr. Thomas C.H. KWONG)

Dear Sirs,

Approval of "Toyo" Bronze Gate Valves

Your letter ref. GWL/11/00581 dated 15 December 2011 refers.

Having considered the test reports by the Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Toyo Valve Co., Ltd.

Country of Origin: Japan

Brand: Toyo

Details of Fittings: (1) 15mm, 20mm, 25mm, 32mm, 40mm and 50mm Bronze PN25 gate valves (no internally applied metallic coating) to BSEN12288, screwed-over bonnet, non-rising stem, threaded ends to BS21, hand wheel operated.

Model No. : Fig. No. 206P

Body Markings :

RED	1
WHITE	125S
	200WOG



- (2) 15mm, 20mm, 25mm, 32mm, 40mm and 50mm
Bronze PN25 gate valves (no internally applied
metallic coating) to BSEN12288 screwed-over
bonnet, non-rising stem, solder joint end to BS864,
hand wheel operated.

Model No. : Fig. No. 207P

Body Markings :

RED	1
WHITE	125S
	200WOG



This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,

(CHIN Chu Sum)
for Water Authority