

NUTEK SYSTEMS, LTD. Unit B, 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street,

Fo Tan, Shatin, N.T., Hong Kong.

Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TEST REPORT

TITLE

Testing of Valve

OUR REFERENCE NO.

J9533-2

DESCRIPTION OF SAMPLE:

Bronze globe valves with female screwed ends; pressure rating PN16; to series B of BS5154; size: A) 25mm, B) 32mm, C) 40mm, D) 50mm,

for both fresh water and sea/salt water application

SAMPLE SUBMITTED BY

Gate Way Valve & Fitting Ltd. Flat F, 22/F., Luk Hop Industrial Bldg.,

8 Luk Hop Street, San Po Kong,

Kowloon, Hong Kong.

MANUFACTURER

Toyo Valve Co., Ltd.

COUNTRY OF ORIGIN

JAPAN

BRAND

TOYO

BODY MARKINGS

| Size of valve (mm) | 100 | Body markings | | | |
|--------------------|----------|----------------|--|--|--|
| 25 | RED | 100 - 1 | | | |
| 32 | WHITE | 100 - 1½ >> | | | |
| 40 | \wedge | 100 − 1½ > | | | |
| 50 | τογο | 100 - 2 | | | |

MODEL

Fig. No. 210

METHOD OF TESTS

BSEN12288: 2003; BSEN12266-1: 2003

PERIOD OF TESTS

4th to 10th March 2003

RESULTS: - (apply only to the samples tested)

1. DIMENSIONS (in millimetres)

| | Sample | | | | |
|-------------------------------------|--------|------|------|------|--|
| | A | В | С | D | |
| Nominal size | 25 | 32 | 40 | 50 | |
| Height of valve, from top to bottom | 110 | 135 | 162 | 179 | |
| Diameter of handwheel | 63 | 70 | 80.3 | 90 | |
| Face to face dimension | 63 | 73 | 82.1 | 98 | |
| Minimum stem diameter | 9.0 | 10.5 | 10.8 | 12.5 | |
| Minimum body wall thickness | 2.5 | 3.0 | 3.5 | 3.0 | |

Note: the female threads at the inlet and outlet of each sample comply with BS21 and ISO7-1.



NUTEK SYSTEMS, LTD.

TEST REPORT

Unit B. 13/F., Universal Ind. Ctr., 23-25 Shan Mei Street. Fo Tan, Shatin, N.T., Hong Kong, Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

OUR REFERENCE NO.J9533-2 (P.2)

2. HYDRAULIC PRESSURE TEST

| | | Nominal | Body test (1.5 PN) | | | Seat test (1.1 PN) | | |
|---------------------|--------------------|-------------------------|---------------------------|--------------|--------|---------------------------|--------------|--------|
| | | pressure PN (bar) | Test pressure (bar) | Duration (s) | Remark | Test pressure (bar) | Duration (s) | Remark |
| mpe | 25mm | 16 | 24 | 15 | Pass | 18 | 15 | Pass |
| | 32mm | 16 | 24 | 15 | Pass | 18 | 15 | Pass |
| | 40mm | 16 | 24 | 15 | Pass | 18 | 15 | Pass |
| | 50mm | 16 | 24 | 15 | Pass | 18 | 15 | Pass |
| BSEN Requirement | 15mm to 54mm | 16 | 24 | 15 | / | 18 | 15 | / |

Note: no leakage was detected during the above test.

3. CHEMICAL COMPOSITION

The following test results apply to valve samples of size 25mm, 32mm, 40mm and 50mm

| | Elements Compositions (%) | | | | | | Designation to | |
|--------------|---------------------------|------|-----|-----|-----|-----|---------------------|----------------------------|
| Component | Cu | Zn | Pb | Sn | Ni | Fe | Other Impurities | Designation to BSEN1982 |
| Body, bonnet | 83.2 | 5.6 | 5.2 | 5.4 | 0.3 | / | 0.3 | CC491K |
| Disc | 83.4 | 5.3 | 5.1 | 5.5 | 0.3 | 7 | 0.4 | CC491K |
| Stem | 61.9 | 34.5 | 2.3 | 0.9 | / | 0.1 | 0.3 | see Note 1 |

Note 1: A further tensile test on this copper alloy material showed that its tensile strength (360N/mm²) and elongation (28.5%) are comparable to those of copper zinc alloy grade CW602N (tensile strength 280-430 N/mm², elongation 15-30%) of BSEN12164 recommended by BSEN12288. Accordingly, this material is considered acceptable.

4. SUMMARY OF RESULTS (apply only to the sample tested)

Dimensions Satisfactory Hydraulic pressure test Satisfactory Chemical composition Satisfactory

Remark:

- 1) The tests shown above were actually performed during the period from 4th to 10th March 2003; the test results were found complying with BS5154: 1991. However, BSEN12288: 2003 was referred to since the test results are found also complying with it.
- 2) The internal water passage surface of all valve samples does not have any metallic coating.

__Authorized signature : _ Notek Systems is a testing agency, Samson W.K. Yiu approved by the Water Authority and Government Supplies Department, tor (Director)

testing water supply fittings.