



水務監督辦事處
Office of the Water Authority

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (3) in WSD 3321/04 Pt.1 T/J(4)

18 March 2004

Gate Way Valve & Fitting Ltd.
Flat F, 22/F., Luk Hop Industrial Building,
8 Luk Hop Street, San Po Kong,
Hong Kong.

(Attn.: Mr. Eric, P. M. MUI)

Dear Sirs,

Approval of "Toyo" Globe Valves

Your letter ref. L-03124TY dated 9 December 2003 refers.

Having considered the test reports by the Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Toyo Valve Co., Ltd.

Country of Origin: Japan

Brand: Toyo


Details of Fitting: 25, 32, 40 and 50mm Bronze globe valves (no internally applied metallic coating), Series B of BS 5154, with female screwed ends.

Model No.: 210

Body Markings:

RED-WHITE

100 - SS



("SS" denotes 1, 1-1/4, 1-1/2 or 2.)


This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

This acceptance letter supersedes the previous letter bearing the Acceptance Reference No. C20040007 dated 26 January 2004.

Yours faithfully,

A handwritten signature in black ink, consisting of a large, stylized 'C' followed by a horizontal stroke and a small loop at the end.

(CHAU Chi Wai, David)
for Water Authority