



水務監督辦事處
Office of the Water Authority

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone **2829 4367**

圖文傳真
Facsimile **2824 0578**

檔號
Reference **(5) in WSD 3321/02 Pt.1 T/J(194)**

10 December 2002

Gate Way Valve & Fitting Ltd.
Flat F, 22/F., Luk Hop Industrial Building,
8 Luk Hop Street, San Po Kong,
Hong Kong.

(Attn.: Mr. Eric P. M. MUI)

Dear Sirs,

Approval of
"Toyo" Bronze Gate Valves and Globe Valves

Your letters ref. L-02120TY and L-02121TY dated 29 November 2002 refer.

Having considered the test reports by the Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Toyo Valve Co., Ltd.

Country of Origin: Japan

Name of Brand: Toyo

Details of Fittings: (1) 25, 40 and 50mm Bronze gate valves to Series B of BS 5154 with female screwed ends (no internally applied metallic coating). Pressure Rating PN25.

Model No.: Fig. No. 204

Body Markings:

RED

WHITE

XX YYYS ZZZWOG



- (2) 15, 22, 28, 35 and 54mm Bronze globe valves to Series B of BS 5154 with solder-joint ends (no internally applied metallic coating). Pressure Rating PN16.

Model No.: Fig. No. 212

Body Markings:

RED - WHITE



ZZZ - XX 

("XX" denotes 1/2, 3/4, 1, 1-1/2, 1-1/4 or 2; and "YYY" denotes 125 or 150; and "ZZZ" denotes 200 or 300.)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,

(CHAU Chi Wai, David)
for Water Authority