



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話 2829 4367
Telephone

圖文傳真 2824 0578
Facsimile

檔號 (4) in WSD 3321/08 Pt.1 T/J(59)
Reference

19 May 2008

Gate Way Valve & Fitting Ltd.
Flat A2, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street, San Po Kong,
Kowloon, Hong Kong.

(Attn.: Mr. Thomas C. H. KWONG)

Dear Sirs,

**Approval of
“Toyo” Bronze Globe Valve**

Your letters ref. L-08126TY dated 26 April 2008 and L-08127TY dated 13 May 2007 refer.

Having considered the test report by the Nutek Systems, Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Toyo Valve Co. Ltd.

Country of Origin: Japan.

Brand: Toyo.

Details of Fitting: 32mm Bronze (gunmetal) globe valve (no internally applied metallic coating) with screwed ends to BS21, pressure rating 25 bar.
Model No.: Fig. No.213.
Body Markings:

RED-WHITE

150 - 1¼



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Yours faithfully,

A handwritten signature in dark ink, appearing to read 'CHIN Chu Sum', with a long, sweeping horizontal stroke extending to the right.

(CHIN Chu Sum)
for Water Authority