



Office of the Water Authority

Immigration Tower
7 Gloucester Road
Hong Kong

水務監督辦事處

香港灣仔
告士打道七號
人民入境事務大樓

Telephone

電話 2829 4446

Facsimile

傳真 2824 0578

Reference

編號 (5) in WSD 3321/98 Pt.1 T/J (25)

Date

日期 3 April 1998

Dear Sirs,

Approval of "BRAY" Butterfly Valves Series 30, 31, 32, 33 & 35/36

Your letter dated 30 March 1998 refers.

It is noted that the fittings described below have been examined, tested and accepted by the Water Research Centre (WRC) to have complied with the United Kingdom Water Bylaws Scheme when correctly installed:-

Name of Manufacturer: Bray Valve & Controls (UK)

Country of Origin: U. K.

Name of Brand: Bray

Details of Fittings: Series 30/31, 32/33 and 35/36 range of butterfly valves manufactured in accordance with BS 5155 having either wafer, lug or double flanged cast iron (600mm only) bodies with either nylon coated ductile iron, stainless steel or aluminium bronze discs. The valve body incorporates an EPDM rubber liner which acts as the seating face for the disc. Maximum working pressure 50 - 300mm (2-12") 16 bar, 350 - 500mm (14-20") 10 bar, 600mm (24") 5 bar.

Size: 50, 65, 80, 100, 125, 150, 200, 250, 300, 350, 400, 450, 500 and 600mm.

Product Designation: Series 30 (wafer), Series 31 (lugged), Series 32 (wafer), Series 33 (wafer), Series 35/36 (double flanged).

Marking: Cast on valve neck, "Bray" and size in metric and imperial.


WRc Directory Ref. No: 9504025 IRN 001

In view of the acceptance by WRc, I have no objection to the use of the said fittings in fresh water supply plumbing system subject to full adherence to waterworks installation requirements.

A condition of this acceptance is that fittings to be installed should be replicas of the samples certified by WRc and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

In applying for the use of the fittings in any project the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'Chan Chi-chiu', written in a cursive style.

(CHAN Chi-chiu)
for Water Authority