



水務署 By Fax to 2773 1164  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件 wsdinfo@wsd.gov.hk  
e-mail

電話 2829 4453  
Telephone

圖文傳真 2824 0578  
Facsimile

檔號 (2) in WSD 33.1/11 Pt.1 T/J(255)  
Reference

18 June 2011

AVK Valves Co., HK Ltd.  
Units C & D, 10/F., Centre 600  
82 King Lam Street  
Cheung Sha Wan,  
Kowloon, Hong Kong

(Attn.: Mr. Henry WONG)

Dear Sirs,

**No Need to Apply for the Pre-installation Approval for  
"AVK" Check Valve**

Your letter ref. AHK/L/11 12373/HW dated 15 November 2011 refers.

In accordance with paragraph 11 in Part II of Schedule 2 of the Waterworks Regulations which requires terminal fittings, such as draw-off taps, stop valves, gate valves, ball valves, mixing valves and combination fittings, to be tested before installation. As check valve is not a terminal fitting, this Authority, at present, does not intend to give a general acceptance or pre-installation approval to non-terminal type of fitting, such as the check valve in question. However, depending on the merits of individual project, the Engineer may require testing of check valve before it can be accepted for installation.

Yours faithfully,

(Tony CHU)  
for Water Authority