

WATER BYELAWS SCHEME

Ref. No: 9501006.12597

Sample No: 94194

25 January 1995

WRc

EVALUATION
& TESTING

C E N T R E

Dear Sir

BACKFLOW PREVENTION DEVICES

1. Samples of the fittings described below have been subjected to relevant tests and examinations contained in WRc Document IQN 5-50-01, and after considering the test reports the Fittings Assessment Panel of the Water Byelaws Scheme finds that the fittings so described comply with, and their use when correctly installed, does not contravene the requirements of Water Byelaws (and Regulations NI).

BACKFLOW PREVENTION DEVICES Schedule C - Check Valve

0034

9501006

IRN 111

'JCH 90' and 'JCH 94' in-line single check valve assemblies consisting of a spring loaded resilient trim check valve cartridge (Watts Ocean type TK model IN, DN15) housed within a DZR brass body.

Size: JCH 90 - DN15 - Min BSP female inlet/outlet.
JCH 94 - DN15 - 15mm compression inlet/outlet.

Product Designation: JCH 90 - DN15 and JCH 94 - DN15.

Marking: Body stamped range name, size, direction of flow arrow and DZR mark.

J C Hansens Metalvarefabrik ApS
(Manufacturer)

Installation Requirements or Notes are set out on Page 3.

2. Fittings (and any non-metallic components contained within them) are re-assessed and, where necessary, retested every 5 years. You will be advised when your product is due for re-assessment. The extent of any testing required for a product will be at the discretion of the Technical Manager.
3. Acceptance for listing entitles you to identify your product with the Scheme's 'WBS Teardrop' Mark. The use of the Mark will make easier the identification of approved products and it is considered to be of commercial benefit. Copies of the 'Mark' are available on request for the purposes of producing artwork.

WRc EVALUATION & TESTING CENTRE, FERN CLOSE, PEN-Y-FAN INDUSTRIAL ESTATE,
OAKDALE, GWENT, NP1 4EH, UK.
TEL: 01495 348484. TELEX: 449641 FAX: 01495 249234.

WRc p.l.c. Registered in England No. 2260096 Registered Office: Hensley Road, Montgomeryshire, PO Box 28, Markon, Buckinghamshire MK7 2HD England



4. Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Fittings Assessment Panel of the Scheme finds that the use of fittings or units, when correctly installed, will not contravene the requirements of the Water Byelaws or (Regulations NI) and that a reference to the fittings will be included in the Scheme's Water Fittings and Materials Directory; this may be abbreviated to 'Water Byelaws Scheme Approved Product' or 'WBS - Approved Product'.
5. Since the incorrect installation of water fittings could result in contravention of the Byelaw requirements, the attention of your customers should be drawn to any Installation Requirements for byelaw compliance set out on Page 3.
6. Would you please supply the Scheme with a copy of any of your company's literature which makes reference to the Scheme's decisions about the products and/or quotes any of the installation requirements.
7. A condition of listing is that no modification to the fittings or units described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Scheme's Panel; failure to comply with this condition may result in the removal from the Water Fittings and Materials Directory of the entry relating to the fittings or units in question.
8. Your products are required to be replicas of the samples described above, and the right is reserved to carry out quality surveillance inspections of your production arrangements, reasonable written notice of which will be given.
9. Please note that the use of the items described in any particular area of supply is at the discretion of the local Water Undertaking.
10. Manufacturers or factors having appliances or units referred to in the Scheme's Directory which incorporate individually approved components and materials are asked to ensure that such components and materials continue to be approved and/or listed in the Directory, during the current period of approval of their appliance. This may require modifications to approved appliances to ensure their retention in the Scheme's Directory. The Scheme must be informed of any such modifications. (See Para. 6).
11. You are reminded (see Form F1, paragraph 5.11) that you must remove your samples from the Fittings Testing Laboratory within four weeks of the date of this letter, after which date the right is reserved to dispose of the samples.

06/12/00

14:35


J.C. HANSENS METALVAREFABRIK APS → 852 2773 1164

- 3 -

16.

12. You are asked to verify the details of your product as set out in Para. 1 and advise us of any discrepancies.

Yours faithfully



Dr G Sandilands
Technical Manager

INSTALLATION REQUIREMENTS OR NOTES

You are advised to draw customers' attention to the fact:

IRN 111 - Byelaws 29, 58 and 73
The fittings is to be so installed as to be readily accessible for examination, repair, replacement or operation.

Mr P E Larsen
Sales Manager
J C Hansens Metalvarefabrik APS
Karelmagervej 21
DK 7100 Vejle
Denmark

FAP/FAM.9501006

WATER BYELAWS SCHEME

Ref. No: 9501007.12598
Sample No: 94195

25 January 1995

WRc

EVALUATION
& TESTING

C E N T R E

Dear Sir

BACKFLOW PREVENTION DEVICES

1. Samples of the fittings described below have been subjected to relevant tests and examinations contained in WRc Document ICN 5-50-01, and after considering the test reports the Fittings Assessment Panel of the Water Byelaws Scheme finds that the fittings so described comply with, and their use when correctly installed, does not contravene the requirements of Water Byelaws (and Regulations NI).

BACKFLOW PREVENTION DEVICES. Schedule C - Check Valve

0034

9501007

IRN 111

'JCH 90' and 'JCH 94' in-line single check valve assemblies consisting of a spring loaded resilient trim check valve cartridge (Watts Ocean type TK model IN, DN 20) housed within a DZR brass body.

Size: JCH 90 - DN20 - 3/4in BSP female inlet/outlet.
JCH 94 - DN20 - 22mm compression inlet/outlet.

Product Designation: JCH 90 - DN20 and JCH 94 - DN20.

Marking: Body stamped range name, size, direction of flow arrow and DZR mark.

J C Hansens Metalvarefabrik ApS
(Manufacturer)

Installation Requirements or Notes are set out on Page 3.

2. Fittings (and any non-metallic components contained within them) are re-assessed and, where necessary, retested every 5 years. You will be advised when your product is due for re-assessment. The extent of any testing required for a product will be at the discretion of the Technical Manager.
3. Acceptance for listing entitles you to identify your product with the Scheme's 'WBS Teardrop' Mark. The use of the Mark will make easier the identification of approved products and it is considered to be of commercial benefit. Copies of the 'Mark' are available on request for the purposes of producing artwork.

WRc EVALUATION & TESTING CENTRE, FERN CLOSE, PEN-Y-FAN INDUSTRIAL ESTATE,
OAKDALE, GWENT, NP1 4EH, UK.
TEL: 01495 245454. TELEX: 449541 FAX: 01495 249234.

WRc plc Registered in England no. 2142021 Registered Office: Henley Road, Macclesfield, Cheshire, SK10 1TF, Macclesfield, Cheshire, SK10 1TF, England



06/12/00

14:35

J.C. HANSENS METALVAREFABRIK APS → 852 2773 1164

NR.707

- 2 -

18

4. Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Fittings Assessment Panel of the Scheme finds that the use of fittings or units, when correctly installed, will not contravene the requirements of the Water Byelaws or (Regulations NI) and that a reference to the fittings will be included in the Scheme's Water Fittings and Materials Directory: this may be abbreviated to "Water Byelaws Scheme - Approved Product" or "WBS - Approved Product".
5. Since the incorrect installation of water fittings could result in contravention of the Byelaw requirements, the attention of your customers should be drawn to any Installation Requirements for byelaw compliance set out on Page 3.
6. Would you please supply the Scheme with a copy of any of your company's literature which makes reference to the Scheme's decisions about the products and/or quotes any of the installation requirements.
7. A condition of listing is that no modification to the fittings or units described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Scheme's Panel; failure to comply with this condition may result in the removal from the Water Fittings and Materials Directory of the entry relating to the fittings or units in question.
8. Your products are required to be replicas of the samples described above, and the right is reserved to carry out quality surveillance inspections of your production arrangements, reasonable written notice of which will be given.
9. Please note that the use of the items described in any particular area of supply is at the discretion of the local Water Undertaking.
10. Manufacturers or factors having appliances or units referred to in the Scheme's Directory which incorporate individually approved components and materials are asked to ensure that such components and materials continue to be approved and/or listed in the Directory, during the current period of approval of their appliance. This may require modifications to approved appliances to ensure their retention in the Scheme's Directory. The Scheme must be informed of any such modifications. (See Para. 6).
11. You are reminded (see Form F1, paragraph 5.11) that you must remove your samples from the Fittings Testing Laboratory within four weeks of the date of this letter, after which date the right is reserved to dispose of the samples.

06/12/00

14:36

J.C. HANSENS METALVAREFABRIK APS + 852 2773 1164

NR. 707

- 3 -

12. You are asked to verify the details of your product as set out in Para. 1 and advise us of any discrepancies.

Yours faithfully



Dr G Sandilands
Technical Manager

INSTALLATION REQUIREMENTS OR NOTES

You are advised to draw customers' attention to the fact:

IRN 111 - Byelaws 29, 58 and 73

The fittings is to be so installed as to be readily accessible for examination, repair, replacement or operation.

Mr P E Larsen
Sales Manager
J C Hansens Metalvarefabrik APS
Karetnagervej 21
DK 7100 Vejle
Denmark

FAP/FAM.9501007

WATER BYELAWS SCHEME

Ref. No: 9501008.12599
Sample No: 94196

25 January 1995

WRc

EVALUATION
& TESTING

C E N T R E

Dear Sir

BACKFLOW PREVENTION DEVICES

1. Samples of the fittings described below have been subjected to relevant tests and examinations contained in WRc Document IGN 5-50-01, and after considering the test reports the Fittings Assessment Panel of the Water Byelaws Scheme finds that the fittings so described comply with, and their use when correctly installed, does not contravene the requirements of Water Byelaws (and Regulations NI).

BACKFLOW PREVENTION DEVICES Schedule C - Check Valve

0034

9501008

IRN 111

JCH 90 and JCH 94 in-line single check valve assemblies consisting of a spring loaded resilient trim check valve cartridge (Watts Ocean type TK model IN, DN25) housed within a DZR brass body.

Size: JCH 90 - DN25 - 1in BSP female inlet/outlet.
JCH 94 - DN25 - 28mm compression inlet/outlet.

Product Designation: JCH 90 - DN25 and JCH 94 - DN25.

Marking: Body stamped range name, size, direction of flow arrow and DZR mark.

J C Hansens Metalvarefabrik ApS (Factor)

Installation Requirements or Notes are set out on Page 3.

2. Fittings (and any non-metallic components contained within them) are re-assessed and, where necessary, retested every 5 years. You will be advised when your product is due for re-assessment. The extent of any testing required for a product will be at the discretion of the Technical Manager.
3. Acceptance for listing entitles you to identify your product with the Scheme's "WBS Teardrop" Mark. The use of the Mark will make easier the identification of approved products and it is considered to be of commercial benefit. Copies of the 'Mark' are available on request for the purposes of producing artwork.

WRc EVALUATION & TESTING CENTRE, FERN CLOSE, PEN-Y-FAN INDUSTRIAL ESTATE,
OAKDALE, GWENT, NP1 4EH, UK.
TEL: 01495 248454. TELEX: 449541 FAX: 01495 249234.

WRc a.l.r. Registered in England No 224299. Registered Office: Henry Road, Madingley, PO Box 14 Marlow, Buckinghamshire SL7 2HD England



4. Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Fittings Assessment Panel of the Scheme finds that the use of fittings or units, when correctly installed, will not contravene the requirements of the Water Byelaws or (Regulations NI) and that a reference to the fittings will be included in the Scheme's Water Fittings and Materials Directory; this may be abbreviated to "Water Byelaws Scheme - Approved Product" or "WBS - Approved Product".
5. Since the incorrect installation of water fittings could result in contravention of the Byelaw requirements, the attention of your customers should be drawn to any Installation Requirements for byelaw compliance set out on Page 3.
6. Would you please supply the Scheme with a copy of any of your company's literature which makes reference to the Scheme's decisions about the products and/or quotes any of the installation requirements.
7. A condition of listing is that no modification to the fittings or units described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Scheme's Panel; failure to comply with this condition may result in the removal from the Water Fittings and Materials Directory of the entry relating to the fittings or units in question.
8. Your products are required to be replicas of the samples described above, and the right is reserved to carry out quality surveillance inspections of your production arrangements, reasonable written notice of which will be given.
9. Please note that the use of the items described in any particular area of supply is at the discretion of the local Water Undertaking.
10. Manufacturers or factors having appliances or units referred to in the Scheme's Directory which incorporate individually approved components and materials are asked to ensure that such components and materials continue to be approved and/or listed in the Directory, during the current period of approval of their appliance. This may require modifications to approved appliances to ensure their retention in the Scheme's Directory. The Scheme must be informed of any such modifications. (See Para. 6).
11. You are reminded (see Form F1, paragraph 5.11) that you must remove your samples from the Fittings Testing Laboratory within four weeks of the date of this letter, after which date the right is reserved to dispose of the samples.

12. You are asked to verify the details of your product as set out in Para. 1 and advise us of any discrepancies.

Yours faithfully



Dr G Sandilands
Technical Manager

INSTALLATION REQUIREMENTS OR NOTES

You are advised to draw customers' attention to the fact:

IRN 121 - Byelaws 29, 50 and 73

The fittings is to be so installed as to be readily accessible for examination, repair, replacement or operation.

Mr P H Larsen
Sales Manager
J C Hansens Metalvarefabrik APS
Karetnagervej 21
DK 7100 Vejle
Denmark

FAP/FOM.9501008

WATER BYELAWS SCHEME

Ref. No: 9501009.12600

Sample No: 94197

25 January 1995

WRc**EVALUATION
& TESTING****C E N T R E**

Dear Sir

BACKFLOW PREVENTION DEVICES

1. Samples of the fittings described below have been subjected to relevant tests and examinations contained in WRc Document IGN 5-50-01, and after considering the test reports the Fittings Assessment Panel of the Water Byelaws Scheme finds that the fittings so described comply with, and their use when correctly installed, does not contravene the requirements of Water Byelaws (and Regulations NI).

BACKFLOW PREVENTION DEVICES
Schedule C - Check Valve

0034

9501009

IRN 111

JCH 90 in-line single check valve assembly consisting of a spring loaded resilient trim check valve cartridge (Watts Ocean type TK model IN, DN32) housed within a DZR brass body.

Size: JCH 90 - DN32 - 1Win BSP female inlet/outlet.

Product Designation: JCH 90 - DN32.

Marking: Body stamped range name, size, direction of flow arrow and DZR mark.

J C Hansens Metalvarefabrik ApS
(Manufacturer)

Installation Requirements or Notes are set out on Page 3.

2. Fittings (and any non-metallic components contained within them) are re-assessed and, where necessary, retested every 5 years. You will be advised when your product is due for re-assessment. The extent of any testing required for a product will be at the discretion of the Technical Manager.
3. Acceptance for listing entitles you to identify your product with the Scheme's "WBS Teardrop" Mark. The use of the Mark will make easier the identification of approved products and it is considered to be of commercial benefit. Copies of the 'Mark' are available on request for the purposes of producing artwork.

WRc EVALUATION & TESTING CENTRE, FERN CLOSE, PEN-Y-FAN INDUSTRIAL ESTATE,
OAKDALE, GWENT NP1 4EH, UK.
TEL: 01495 248454. TELEX: 444541 FAX: 01495 249234.

WRc s.l.c. Registered in England No. 2280000. Registered Office: Henley Road, Maidenhead, PO. Box 30, Maidenhead, Berkshire SL7 2PD, England.



4. Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Fittings Assessment Panel of the Scheme finds that the use of fittings or units, when correctly installed, will not contravene the requirements of the Water Byelaws or (Regulations NI) and that a reference to the fittings will be included in the Scheme's Water Fittings and Materials Directory: this may be abbreviated to "Water Byelaws Scheme - Approved Product" or "WBS - Approved Product".
5. Since the incorrect installation of water fittings could result in contravention of the Byelaw requirements, the attention of your customers should be drawn to any Installation Requirements for byelaw compliance set out on Page 3.
6. Would you please supply the Scheme with a copy of any of your company's literature which makes reference to the Scheme's decisions about the products and/or quotes any of the installation requirements.
7. A condition of listing is that no modification to the fittings or units described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Scheme's Panel; failure to comply with this condition may result in the removal from the Water Fittings and Materials Directory of the entry relating to the fittings or units in question.
8. Your products are required to be replicas of the samples described above, and the right is reserved to carry out quality surveillance inspections of your production arrangements, reasonable written notice of which will be given.
9. Please note that the use of the items described in any particular area of supply is at the discretion of the local Water Undertaking.
10. Manufacturers or factors having appliances or units referred to in the Scheme's Directory which incorporate individually approved components and materials are asked to ensure that such components and materials continue to be approved and/or listed in the Directory, during the current period of approval of their appliance. This may require modifications to approved appliances to ensure their retention in the Scheme's Directory. The Scheme must be informed of any such modifications. (See Para. 6).
11. You are reminded (see Form F1, paragraph 5.11) that you must remove your samples from the Fittings Testing Laboratory within four weeks of the date of this letter, after which date the right is reserved to dispose of the samples.

12. You are asked to verify the details of your product as set out in Para. 1 and advise us of any discrepancies.

Yours faithfully



G. Sandilands
Technical Manager

INSTALLATION REQUIREMENTS OR NOTES

You are advised to draw customers' attention to the fact:

IPN 1.1 - Byelaws 29, 58 and 73

The fittings is to be so installed as to be readily accessible for examination, repair, replacement or operation.

Mr P M Larsen
Sales Manager
J C Hansens Metalvarefabrik APS
Karetnagervej 21
DK 7100 Vejle
Denmark

FAP/P.M.9501009

WATER BYELAWS SCHEME

Ref. No: 9501010.12601

Sample No: 94198

25 January 1995

WRC**EVALUATION
& TESTING****C E N T R E**

Dear Sir

BACKFLOW PREVENTION DEVICES

1. Samples of the fittings described below have been subjected to relevant tests and examinations contained in WRC Document ICN 5-50-01, and after considering the test reports the Fittings Assessment Panel of the Water Byelaws Scheme finds that the fittings so described comply with, and their use when correctly installed, does not contravene the requirements of Water Byelaws (and Regulations NI).

**BACKFLOW PREVENTION DEVICES
Schedule C - Check Valve**

0034

9501010

IRN 111

'JCH 90' in-line single check valve assembly consisting of a spring loaded resilient trim check valve cartridge (Watts Ocean type TK model IN, DN40) housed within a DZR brass body.

Size: JCH 90 - DN40 - 1 1/2 in BSP female inlet/outlet.

Product Designation: JCH 90 - DN40.

Marking: Body stamped range name, size, direction of flow arrow and DZR mark.

J C Hansens Metalvarefabrik ApS
(Manufacturer)

Installation Requirements or Notes are set out on Page 3.

2. Fittings (and any non-metallic components contained within them) are re-assessed and, where necessary, retested every 5 years. You will be advised when your product is due for re-assessment. The extent of any testing required for a product will be at the discretion of the Technical Manager.
3. Acceptance for listing entitles you to identify your product with the Scheme's 'WBS Teardrop' Mark. The use of the Mark will make easier the identification of approved products and it is considered to be of commercial benefit. Copies of the 'Mark' are available on request for the purposes of producing artwork.

WRC EVALUATION & TESTING CENTRE, FERN CLOSE, PEN-Y-FAN INDUSTRIAL ESTATE,
OAKDALE, GWENT, NP1 4EH, UK.
TEL: 01495 248454. TELEX: 449541 FAX: 01495 249234.

WRC Ltd. Registered in England No. 2260796 Registered Office: Henley Road, Watlington, Oxfordshire OX1 2HU England



05/12/00

14:39

J.C. HANSENS METALVAREFABRIK APS -> 852 2773 1164

NR.707

- 2 -

27

4. Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Fittings Assessment Panel of the Scheme finds that the use of fittings or units, when correctly installed, will not contravene the requirements of the Water Byelaws or (Regulations NI) and that a reference to the fittings will be included in the Scheme's Water Fittings and Materials Directory: this may be abbreviated to "Water Byelaws Scheme - Approved Product" or "WBS - Approved Product".
5. Since the incorrect installation of water fittings could result in contravention of the Byelaw requirements, the attention of your customers should be drawn to any Installation Requirements for byelaw compliance set out on Page 3.
6. Would you please supply the Scheme with a copy of any of your company's literature which makes reference to the Scheme's decisions about the products and/or quotes any of the installation requirements.
7. A condition of listing is that no modification to the fittings or units described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Scheme's Panel; failure to comply with this condition may result in the removal from the Water Fittings and Materials Directory of the entry relating to the fittings or units in question.
8. Your products are required to be replicas of the samples described above, and the right is reserved to carry out quality surveillance inspections of your production arrangements, reasonable written notice of which will be given.
9. Please note that the use of the items described in any particular area of supply is at the discretion of the local Water Undertaking.
10. Manufacturers or factors having appliances or units referred to in the Scheme's Directory which incorporate individually approved components and materials are asked to ensure that such components and materials continue to be approved and/or listed in the Directory, during the current period of approval of their appliance. This may require modifications to approved appliances to ensure their retention in the Scheme's Directory. The Scheme must be informed of any such modifications. (See Para. 6).
11. You are reminded (see Form F1, paragraph 5.11) that you must remove your samples from the Fittings Testing Laboratory within four weeks of the date of this letter, after which date the right is reserved to dispose of the samples.

05/12/00

14:40

J.C. HANSENS METALVAREFABRIK APS + 852 2773 1164


NR. 707

02

3

12. You are asked to verify the details of your product as set out in para. 1 and advise us of any discrepancies.

Yours faithfully



Dr G Sandilands
Technical Manager

INSTALLATION REQUIREMENTS OR NOTES

You are advised to draw customers' attention to the fact:

IRN 111 - Byelaws 29, 58 and 73
The fittings is to be so installed as to be readily accessible for examination, repair, replacement or operation.

Mr P E Larsen
Sales Manager
J C Hansens Metalvarefabrik APS
Karetnagervej 21
DK 7100 Vejle
Denmark

FAP/FAM.9501010

WATER BYELAWS SCHEME

Ref. No: 9501011.12602
Sample No: 94199

25 January 1995

WRc

EVALUATION
& TESTING

C E N T R E

Dear Sir

BACKFLOW PREVENTION DEVICES

1. Samples of the fittings described below have been subjected to relevant tests and examinations contained in WRc Document IGM 5-50-01, and after considering the test reports the Fittings Assessment Panel of the Water Byelaws Scheme finds that the fittings so described comply with, and their use when correctly installed, does not contravene the requirements of Water Byelaws (and Regulations NI).

BACKFLOW PREVENTION DEVICES Schedule C - Check Valve

0034

9501011 IRN 111
'JCH 90' in-line single check valve assembly consisting of a spring loaded resilient trim check valve cartridge (Watts Ocean type TK model IN, DN50) housed within a DZR brass body.

Size: JCH 90 - DN50 2in BSP female inlet/outlet.

Product Designation: JCH 90 - DN50.

Marking: Body stamped range name, size, direction of flow arrow and DZR mark.

J C Hansens Metalvarefabrik ApS
(Manufacturer)

(Installation Requirements or Notes are set out on Page 3.

2. Fittings (and any non-metallic components contained within them) are re-assessed and, where necessary, retested every 5 years. You will be advised when your product is due for re-assessment. The extent of any testing required for a product will be at the discretion of the Technical Manager.
3. Acceptance for listing entitles you to identify your product with the Scheme's 'WBS Teardrop' Mark. The use of the Mark will make easier the identification of approved products and it is considered to be of commercial benefit. Copies of the 'Mark' are available on request for the purposes of producing artwork.

WRc EVALUATION & TESTING CENTRE, FERN CLOSE, PEN-Y-FAY INDUSTRIAL ESTATE,
OAKDALE, CVENT NP1 4EH, UK.
TEL: 01495 244454. TELEX: 449541 FAX: 01495 249234

WRc p.l.c. Registered in England No. 2282088. Registered Office: Monsey Road, Middlesbrough, P.O. Box 16 Middlesbrough, Cleveland TS1 1HD England



4. Manufacturers or applicants may only quote in their sales literature, terms used in this letter when indicating the decision of the Panel in respect to their fittings, namely that the Fittings Assessment Panel of the Scheme finds that the use of fittings or units, when correctly installed, will not contravene the requirements of the Water Byelaws or (Regulations NI) and that a reference to the fittings will be included in the Scheme's Water Fittings and Materials Directory: this may be abbreviated to "Water Byelaws Scheme - Approved Product" or "WBS - Approved Product".
5. Since the incorrect installation of water fittings could result in contravention of the Byelaw requirements, the attention of your customers should be drawn to any Installation Requirements for byelaw compliance set out on Page 3.
6. Would you please supply the Scheme with a copy of any of your company's literature which makes reference to the Scheme's decisions about the products and/or quotes any of the installation requirements.
7. A condition of listing is that no modification to the fittings or units described above shall be made without first notifying the Scheme and submitting details of the modification and, if so required, samples of the fitting or unit as so modified for consideration by the Scheme's Panel; failure to comply with this condition may result in the removal from the Water Fittings and Materials Directory of the entry relating to the fittings or units in question.
8. Your products are required to be replicas of the samples described above, and the right is reserved to carry out quality surveillance inspections of your production arrangements, reasonable written notice of which will be given.
9. Please note that the use of the items described in any particular area of supply is at the discretion of the local Water Undertaking.
10. Manufacturers or factors having appliances or units referred to in the Scheme's Directory which incorporate individually approved components and materials are asked to ensure that such components and materials continue to be approved and/or listed in the Directory, during the current period of approval of their appliance. This may require modifications to approved appliances to ensure their retention in the Scheme's Directory. The Scheme must be informed of any such modifications. (See Para. 6).
11. You are reminded (see Form F1, paragraph 5.11) that you must remove your samples from the Fittings Testing Laboratory within four weeks of the date of this letter, after which date the right is reserved to dispose of the samples.

- 3 -

12. You are asked to verify the details of your product as set out in Para. 1 and advise us of any discrepancies.

Yours faithfully



Dr G Sandilands
Technical Manager

INSTALLATION REQUIREMENTS OR NOTES

You are advised to draw customers' attention to the fact:

IRN 101 - Byelaws 29, 58 and 73

The fittings is to be so installed as to be readily accessible for examination, repair, replacement or operation.

Mr P E Larsen
Sales Manager
J C Hansens Metalvarefabrik APS
Karetnagervej 21
DK 7100 Vejle
Denmark

FAP/FAM.9501011