

OFFICE OF THE WATER AUTHORITY 水務監督辦事處

LEIGHTON CENTRE 12/F, 77 LEIGHTON ROAD, HONG KONG

香港德輔道七十七號十二樓

Tel. No.: 5-7900396

Ref. No.: (3) in WWO 3321/82 XIV T/J (8)

Acceptance Reference No. 850056

RECEIVED 30 JUL 1985

24 July 1985

Dear Sir,

Val-Matic Check Valves

Your letter ref. M12774/85 dated 4 June 1985 refers.

Samples of the water fittings described below have been examined. After considering the test reports by CEMEC Engineering Co Ltd this Authority finds that the fittings comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Waterworks Regulations.

Name of Manufacturer : Val-Matic Valve and Manufacturing Corp.

Country of Origin : U.S.A.

Size and Model Nos. : (a) 65 mm, 80 mm, 100 mm, 150 mm and 200 mm dia. wafer style silent check valve; cast iron body; bronze trim; stainless steel spring; pressure rating PN16; flanges to ANSI Class 125

Model ref: 1400 series

Body Marking: (for 150 mm dia.) IF 706-1
(for 200 mm dia.) 708-1


(b) 80 mm, 100 mm and 150 mm dia. wafer style silent check valve; cast iron body; stainless steel trim and spring; pressure rating PN16; flanges to ANSI Class 125

Model ref: 1400 series

Body Marking: (for 80 mm dia.) 703-11F
(for 150 mm dia.) IF 706-1

(c) 65 mm, 80 mm, 100 mm, 150 mm and 200 mm dia. wafer style dual disc check valve; cast iron body; aluminium bronze disc and stainless steel spring; pressure rating PN16; flanges to ANSI Class 125

Model ref: 8800 series


Body Marking: 

There is no objection to the above water fittings being offered for sale subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that fittings to be installed should be replicas of the samples submitted for test and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the samples submitted for test or if complaints are received regarding malfunction or inadequacy of the fittings.

In applying for the use of the fittings in any project the Acceptance Reference number at the top left hand corner of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully



(YEUNG On-ching)
for Water Authority