



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4367

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (2) in WSD 3321/16 Pt.1 T/J(924)

24 June 2016

Gate Way Valve & Fitting Ltd.  
Flat A1, 4/F, Galaxy Factory Building,  
25-27 Luk Hop Street,  
San Po Kong, Kowloon,  
Hong Kong

(Attn.: Mr Jack HO)

Dear Sir,

### Approval of "TOYO" Gate Valves

Your letter ref. GWL/16/00004 dated 7 June 2016 refers.

Having considered test report ref. DP-SUMMARY-2016-28 issued on 8 June 2016 by the Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Kitz (Thailand) Ltd.  
**Country of Origin:** Thailand  
**Brand:** Toyo  
**Details of Fitting:** Copper alloy gate valves  
**Model:** Fig. No. 207  
**Size:** DN15, 22, 28, 35, 42, 54  
**Body Markings:** RED WHITE TOYO 125S

**Expiry Date:**

9 May 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)  
for Water Authority

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/CS(MC)       ] - with soft copy only