



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (7) in WSD 3321/13 Pt.1 T/J(112)

20 June 2013

Purdon King (International) Ltd.
19/F, Tak Lee Commercial Building,
113-117 Wan Chai Road,
Hong Kong

(Attn.: Ms Susan SIM)

Dear Madam,

Approval of "PEGLER" Stop Valves

Your letters dated 10 March 2009, 8 May 2013, 22 May 2013 and 10 June 2013 refer.

Brand	Model	Size	Castco Test Report Ref. Nos.
Pegler	PB100	1/2"	DP0130327-138 DIM, DP0130327-138 HYD, MS0130327-1, MO0130327-34
		3/4"	DP0130327-139 DIM, DP0130327-139 HYD, MS0130327-2, MO0130327-35
		1"	DP0130327-140 DIM, DP0130327-140 HYD, MS0130327-3, MO0130327-36

Having considered the above test reports issued on 10 April 2013, 27 April 2013 and 3 June 2013 by the Castco Testing Centre Ltd. and the test reports ref. J13427A-1, J13427B-1 & J13427C-1 issued by the Nutek Systems Ltd. on 6 March 2009, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Pegler Yorkshine Group Ltd.

Country of Origin: U. K.

Brand: Pegler

Details of Fittings: ½", ¾" and 1" Chrome plated brass ball valve with female screwed ends to BS21 and red lever handle.
Model no.: PB100

Body Markings: 1/2 PN25 20120410 (for ½" stop valve) or
3/4 PN25 20110314 (for ¾" stop valve) or
1 PN25 20120701 (for 1" stop valve)
or

PEGLER XXX (where XXX denotes ½, ¾, or 1)
ENGLAND PN 25

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.


A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

This acceptance letter is to supersede the acceptance letter no. C20090028 in ref. (5) in WSD 3321/09 Pt.1 T/J(38) issued on 16 March 2009. You are required to return the above letter for cancellation.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,



(WONG Kwok Hung)
for Water Authority