



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(44)

2 March 2017

Gate Way Valve & Fitting Ltd.
Flat A1, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street,
San Po Kong, Kowloon,
Hong Kong

(Attn.: Mr Jack HO)

Dear Sir,

Approval of “VALMATIC” Check Valves

Your letters ref. GWL/17/0118 and GWL/17/0118-2 dated 18 January 2017 and 13 February 2017 respectively refer.

Having considered the test report ref. BC-SUMMARY-2016-50 issued on 30 August 2016 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Val-Matic Valve & Manufacturing Corp
Country of Origin:	China
Brand:	Valmatic
Details of Fitting:	Cast iron silent check valve (with epoxy coating under WRAS approval no. 1701509)
Model and Size:	1402AHKXF – 50mm 1425AHKXF – 65mm 1403AHKXF – 80mm

1404AHKXF – 100mm
1406AHKXF – 150mm
1408AHKXF – 200mm

Body Markings: VAL MATIC CORP.

Expiry Date: 2 August 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fire services subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only