



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/16 Pt.1 T/J(1598)

7 February 2017

Approval of “CLA-VAL” Pressure Reducing Valves

Your letters ref. GWL/16/00013, GWL/16/00013-R1 and GWL/16/00013-R2 dated 24 November 2016, 4 January 2017 and 19 January 2017 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Cla-Val Europe

Country of Origin: China

Brand: Cla-Val

Details of Fitting: Range of adjustable, in-line pressure reducing valves with a (coated ductile iron body) and EPDM seal. Maximum inlet supply pressure 25.0 bar. Maximum outlet pressure 2.0 bar to 14.0 bar. Cold water use only. (with epoxy powder coating under WRAS approval no. 1503518)

Model: AQUA 80-960B
Size: 40mm, 50mm, 65mm, 80mm, 100mm, 125mm, 150mm
Marking: Cla-Val, DN, PN and flow arrow on body
Model, Cla-Val and technical information on data plate

WRAS Approval Number: 1309329

Installation Requirements: R001, R120

Expiry Date: 30 September 2018

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fire services subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



AQUA 80-960B