



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4367

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (6) in WSD 3321/15 Pt.1 T/J(632)

10 December 2015

Gate Way Valve & Fitting Ltd  
Flat A1, 4/F, Galaxy Factory Building,  
25-27 Luk Hop Street, San Po Kong,  
Kowloon, Hong Kong

(Attn.: Mr. Eric MUI)

Dear Sir,

### Approval of Honeywell Pressure Reducing Valve

Your letter ref. no. GWL/15/00577WS dated 4 December 2015 and subsequent supplements received by this office dated 9 December 2015 and 10 December 2015 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

**Name of Manufacturer:** Honeywell GmbH

**Country of Origin:** Germany

**Brand:** Honeywell

**Details of Fittings:** Ranges of in-line, manually adjustable pressure reducing valves with DZR brass or stainless steel bodies and NBR seat washers & 'O' rings. Minimum and maximum regulated outlet pressures; D06F range: 1.5 - 6 bar. D06FN range: 0.5 - 2 bar. D06FI range: 1.5 - 6 bar. Maximum working pressure 25.0 bar. Cold water use only.

**Sizes:** ½” , ¾”, 1”, 1 ¼”, 1 ½”, 2” BSP inlet/outlets

**Models:** D06F  
D06FN  
D06FI

**Marking:** Honeywell or ‘H’ logo model, size, direction of flow arrow and DR & PN on bodies.  
Kiwa, DVGW, DW-6330 & operating info on spring housing.

**WRAS Approval Number:** 1210041

**Installation Requirements:** R001, R120

**Expiry Date:** 31 October 2017

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance letter is only applicable to main body of the fittings, unless otherwise specified.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms. K L FOK at tel. no. 2829 5657.

Yours faithfully,



(LAM Ching Man)  
for Water Authority

c.c.      WSD 3321/1/82 ] - without catalogue  
            E/CS(TS)1    ]