



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (5) in WSD 3321/15 Pt.1 T/J(344)

7 December 2015

Gate Way Valve & Fitting Ltd
Flat A2, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street,
San Po Kong, Kowloon,
Hong Kong

(Attn.: Mr Eric MUI)

Dear Sir,

Approval of "HONEYWELL" Pressure Reducing Valves

Your letters ref. L-15128HW and L-15128HW-2 dated 16 September 2015 and 30 November 2015 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Honeywell GmbH

Country of Origin: Germany

Brand: HONEYWELL

Details of Fittings: (1) Range of adjustable in-line pressure reducing valves with blue epoxy coated cast iron bodies, EPDM gaskets and 'O'-rings. Cold water use only. Minimum outlet pressure 1.5 bar. Maximum outlet pressure 6.5 bar. Maximum working pressure 16.0 bar. (Epoxy powder coating is fusion and under WRAS approval no. 1411519).

Model: D15S

Sizes: DN65, DN80 and DN100

Marking: Honeywell, direction of flow arrow, model, pressure, size, operating info on bodies, Honeywell Braukmann on gauge.

WRAS Approval Number: 1405056

Installation Requirement: R001

Expiry Date: 31 May 2019

- (2) Range of manually adjustable, spring loaded, diaphragm operated pressure reducing valves with blue epoxy coated cast iron bodies, DZR brass diaphragm plates and stainless steel valve shafts. The outlet pressure is adjusted by a screw located on the top of the bonnet. Maximum inlet pressure 16.0 bar. Working pressures from 1.5 to 8.0 bar. Cold water use only. (Epoxy powder coating is fusion and under WRAS approval no. 1411519).

Model: D15P

Sizes: DN50, DN125 and DN150

Marking: Honeywell, model number, min/max outlet pressures on an adhesive label on body. PN, DN, flow arrow, 'BRAUKMAN' and D15 cast on valve body.

WRAS Approval Number: 1404083

Installation Requirement: R001, R120

Expiry Date: 30 April 2019

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –


“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms. K L FOK at tel. no. 2829 5657.

Yours faithfully,


(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
E/CS(TS)1]