



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/17 Pt.1 T/J(416)

16 May 2017

Tozen (H.K.) Limited
Unit 1607, 16/F., Ho Lik Centre,
66A Sha Tsui Road, Tsuen Wan,
N.T., Hong Kong

(Attn.: Mr Franki LAW)

Dear Sir,

Approval of "TOZEN" Flexible Joint

Your letters ref. TLL/M773/17 and TLL/M776/17 dated 12 April 2017 and 26 April 2017 respectively refer.

Having considered the test report ref. J20663Br1 issued on 25 April 2017 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below comply with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tozen Corporation
Country of Origin: China
Brand: Tozen
Details of Fitting: Stainless steel flexible joint
Model: SF600
Size: 20mm

Body Markings:

BS 4504 16BAR NOM 15A

BRAND: TOZEN	TYPE: SF600	BELLOWS	BRAID	SLEEVE X:	FLANGE
N.D: 20MM	W/P: 16	SUS: 304	SUS: 304	SUS Y:	BSPN16

Expiry Date: 9 February 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply system mentioned above.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only