



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail      wsdinfo@wsd.gov.hk

電話  
Telephone      2829 4355

圖文傳真  
Facsimile      2824 0578

檔號  
Reference      ( 5 ) in WSD 3321/16 Pt.1 T/J(1359)

19 October 2016

Waterfront Fluid Controls Limited  
Flat A2, 4/F, Galaxy Factory Building,  
25-27 Luk Hop Street, San Po Kong,  
Kowloon, Hong Kong

(Attn.: Mr Terence LEONG)

Dear Sir,

**Approval of “WATERFRONT” Flexible Connectors**

Your letters ref. L16W300, L16W327 and L16W340 dated 23 September 2016, 30 September 2016 and 7 October 2016 respectively refer.

Having considered the test report ref. DP-SUMMARY-2016-40 issued on 5 October 2016 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

<b>Name of Manufacturer:</b>	Waterfront Fluid Controls Ltd
<b>Country of Origin:</b>	Indonesia
<b>Brand:</b>	Waterfront
<b>Details of Fitting:</b>	Twin sphere union joint rubber flexible connector
<b>Model:</b>	WRU
<b>Size:</b>	20mm, 25mm, 32mm, 40mm, 50mm
<b>Body Markings:</b>	WRU 16 bar

**Expiry Date:** 31 March 2021

**Proviso:** The fittings can only be used in non-potable water plumbing system.


This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no: 2294 2656.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only