



TEST REPORT

TITLE : Testing of valve
 OUR REFERENCE : J5116B
 DESCRIPTION OF SAMPLE : 25mm (1") cast iron air release valve
 SAMPLE SUBMITTED BY :
 BRAND : Valmatic Valve & Manufacturing Corp.
 MODEL : 15A.3
 TEST REQUIRED : Hydraulic pressure test
 PERIOD OF TESTS : 30th March 1999

RESULTS: - HYDRAULIC PRESSURE TEST

	Body test			Seat test		
	Test pressure (bar)	Duration (s)	Remark	Test pressure (bar)	Duration (s)	Remark
Sample	25	30	Pass	25	60	Pass

Note : no leakage was detected during the above test.

DATE : 4th May 1999 CERTIFIED BY:

Nutek Systems is a testing agency, approved by the Water Authority and Government Supplies Department, for testing water supply fittings.

For E.A. Bruges
BSc PhD CEng FIMarE
FIMechE FHKIE MASME
MASHRAE
Director & General Manager