

# SURGEBUSTER® SWING CHECK VALVE

SERIES NO. 7200 & 7200A ANSI CLASS 125

## STANDARD MATERIALS OF CONSTRUCTION

<u>PART NO.</u>	<u>PART NAME</u>	<u>MATERIAL</u>
1	BODY BODY	DUCTILE IRON ASTM A536, GRADE 65-45-12 (250 CWP) CAST IRON ASTM A126, CLASS B (150 CWP)
2	COVER COVER	DUCTILE IRON ASTM A536, GRADE 65-45-12 (250 CWP) CAST IRON ASTM A126, CLASS B (150 CWP)
3	DISC	BUNA-N W/ ALLOY STEEL & NYLON REINFORCEMENT
4	COVER SEAL (4"-48") COVER SEAL (2"-3")	BUNA-N ASTM D2000 COMPRESSED NON-ASBESTOS FIBER
5A	COVER BOLT	ALLOY STEEL SAE J429 GRADE 5, PLATED
5B	COVER BOLT NUT (4"-12")	ALLOY STEEL SAE J429 GRADE 5, PLATED
5C	WASHER	ALLOY STEEL, PLATED
13	DISC ACCELERATOR	STAINLESS STEEL, TYPE 302

NOTE: ALL SPECIFICATIONS AS  
LAST REVISED.

Revised 3-13-13

## MATERIALS OF CONSTRUCTION

DATE 5/21/03



VALVE AND MANUFACTURING CORP.

DRWG. NO.

VM-7202-M