

## 水 務 署 Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 Our ref.

: (6) in WSD 3321/19 T/J(459/2019)

電話

Tel.

來函檔號 Your ref.

傳真 Fax.

: 2824 0578

23 August 2019

Gate Way Valve & Fitting Ltd. Flat A1, 4/F, Galaxy Factory Building, 25-27 Luk Hop Street, San Po Kong, Kowloon, Hong Kong

(Attn.: Mr Jack HO)

Dear Sir,

## Approval of "TOYO" Strainers (General Acceptance No. C20190432FS)

Your letters ref. GWL/19/517, GWL/19/0624 and GWL/19/0517-R1 dated 17 May 2019, 24 June 2019 and 8 August 2019 respectively refer.

Having considered the test report ref. BC-SUMMARY-2019-21 issued on 11 April 2019 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

**Kitz Corporation** 

**Country of Origin:** 

the Mainland of China

**Brand:** 

Toyo

**Details of Fitting:** 

Cast iron Y-strainer

Model:

381EHK

Size:

65mm, 80mm, 100mm, 125mm, 150mm, 200mm,

250mm, 300mm

**Body Markings:** 

TOYO size in DN PN16 CI





**Expiry Date:** 

7 April 2024

**Proviso:** The fittings can only be used in fresh water fire services systems.

This Authority hereby permits the use of the above fittings in fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire services systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c.

WSD 3321/1/82 ] - without catalogue ME/MC ] - with soft copy only