



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(822/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 August 2020

Gate Way Valve & Fitting Ltd.
Flat A1, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street, San Po Kong,
Kowloon, Hong Kong

(Attn.: Mr Jack HO)

Dear Sir,

**Approval of "TOYO" Globe Valves
(General Acceptance No. C20200670)**

Your letters ref. GWL/20/0623 and GWL/20/0623-A1 dated 23 June 2020 and 16 July 2020 respectively refer.

Having considered the test report ref. BC-SUMMARY-2019-40 issued on 27 June 2019 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kitz Corporation
Country of Origin: the Mainland of China
Brand: Toyo
Details of Fittings: Cast iron globe valve with epoxy powder coating under WRAS approval no. 2008501
Model: 510SHHK
Size: 65mm, 80mm, 100mm, 150mm, 200mm
Body Markings: (DN) PN16 CI TOYO ←



Expiry Date: 13 June 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only