



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(493/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

26 April 2021

Gate Way Valve & Fitting Ltd.
Flat A1, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street, San Po Kong,
Kowloon, Hong Kong

(Attn.: Mr Stephen LAM)

Dear Sir,

**Approval of "AVK" Gate Valves
(General Acceptance No. C20210428)**

Your letters ref. GWL/21/0322 and GWL/21/0413 dated 22 March 2021 and 13 April 2021 respectively refer.

Having considered the test report ref. BC-SUMMARY-2021-022 issued on 11 January 2021 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	AVK International A/S
Country of Origin:	Denmark
Brand:	AVK
Details of Fittings:	Cast iron gate valve with epoxy powder coating under WRAS approval no. 1701509
Model:	02/40
Size:	50mm, 65mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm



香港環境卓越大獎
Hong Kong Award for Environmental Excellence



10 years +
關心服務
caringorganisation
Awarded by The Hong Kong Council of Social Service
新加坡社會服務委員會

Body Markings: AVK (DN) PN16 GG CI

Expiry Date: 31 January 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only