



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(44/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

18 March 2021

Gate Way Valve & Fitting Ltd.
Flat A1, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street,
San Po Kong, Kowloon,
Hong Kong

(Attn.: Mr Jack HO)

Dear Sir,

**Approval of “VALVULAS CT” Float Operated Valves
(General Acceptance No. C20210284)**

Your letters ref. GWL/20/1215 and GWL/21/0226 dated 15 December 2020 and 26 February 2021 respectively refer.

Having considered the test report ref. BC-SUMMARY-2020-165 issued on 28 November 2020 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Genwec Washroom SL
Country of Origin: Spain
Brand: Valvulas CT
Details of Fitting: Stainless steel float operated valve
Model: 200A-RPH
Size: 20mm, 25mm, 32mm, 40mm, 50mm
Body Markings: CT AISI 316L



Expiry Date: 26 November 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only