

消 防 處  
牌 照 及 審 批 總 區  
香 港 九 龍 尖 沙 咀 東 部 康 莊 道 1 號  
消 防 總 部 大 廈 5 樓



**FIRE SERVICES DEPARTMENT**  
**LICENSING AND CERTIFICATION COMMAND**  
5/F, Fire Services Headquarters Building,  
No.1 Hong Chong Road, Tsim Sha Tsui East,  
Kowloon, Hong Kong.

本處檔號 OUR REF.: (7) in FP/208/0003(II)  
個案編號 LIFIPS No.: 1142849  
來函檔號 YOUR REF.: -  
電子郵件 E-mail: lcpolic2@hkfsd.gov.hk  
圖文傳真 FAX: (852) 2367 3631  
電 話 TEL NO.: (852) 2733 7605

3 November 2021

Gate Way Valve & Fitting Ltd.  
Flat A1, 4/F, Galaxy Factory Building,  
No. 25-27 Luk Hop Street, San Po Kong,  
Kowloon, Hong Kong

Dear Sir/Madam,

**Application for Acceptance of  
Pressure Reducing Valve Cal-Val model 90-01 & 690-01**

I refer to my interim reply of 3 September 2021 on the captioned subject.

Please be informed that according to FSD Circular Letter No. 3/2020, if a piece of Fire Service Installations and Equipment (FSI) (except portable equipment) is being listed by one of the Product Certification Bodies (PCBs), e.g. SAI Global Certification Service Pty Limited (SAI), it is deemed to be accepted by this Department subject to such FSI, its application and installation being in conformity with all relevant local requirements. In this regard, application to this Department for prior product approval / acceptance of listed FSI is not required. I append hereunder the website address of the above-mentioned FSD Circular Letter No. 3/2020 for your reference:

[https://www.hkfsd.gov.hk/eng/source/circular/2020\\_03\\_eng\\_20200721\\_123921.pdf](https://www.hkfsd.gov.hk/eng/source/circular/2020_03_eng_20200721_123921.pdf)

Besides, please also download the 'REMINDER: Acceptance of Listed Products' via the following FSD website for your reference.

[http://www.hkfsd.gov.hk/eng/source/licensing/product/fsi\\_reminder\\_listed.pdf](http://www.hkfsd.gov.hk/eng/source/licensing/product/fsi_reminder_listed.pdf)

Please contact Senior Station Officer TSANG Chun-hei at 2733 7666 should you need any amplifications.

Yours faithfully,

(WONG Ka-shun)  
for Director of Fire Services

WKS/tch