



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1134/2021)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

16 September 2021

Waterfront Fluid Controls Limited
Flat A2, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street, San Po Kong,
Kowloon, Hong Kong

(Attn.: Mr Terence LEONG)

Dear Sir,

**Approval of “WATERFRONT” Flexible Joints
(General Acceptance No. C20211062FS)**

Your letters ref. L21W352 and L21W371 dated 22 July 2021 and 3 August 2021 respectively refer.

Having considered the test report ref. 210622-2079 issued on 30 July 2021 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Waterfront Fluid Controls Ltd

Country of Origin: Indonesia

Brand: Waterfront

Details of Fittings: Twin sphere rubber flexible joint

Model: WRU

Size: 20mm, 25mm, 32mm, 40mm, 50mm

Body Markings: (Size) WRU 

Expiry Date: 20 June 2026

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire services systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only