



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(897/2022)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

21 September 2022

Gate Way Valve & Fitting Ltd.  
Flat A1, 4/F, Galaxy Factory Building,  
25-27 Luk Hop Street,  
San Po Kong, Kowloon,  
Hong Kong

(Attn.: Mr Stephen LAM)

Dear Sir,

**Approval of “CLA-VAL” Check Valves  
(General Acceptance No. C20220876)**

Your letters ref. GWL/22/0727 and GWL/22/0822-580P-RS dated 27 July 2022 and 22 August 2022 respectively refer.

Having considered the test report ref. BC-SUMMARY-2022-064 issued on 7 June 2022 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Cla-Val Pacific Ltd  
**Country of Origin:** New Zealand  
**Brand:** Cla-Val  
**Details of Fitting:** Ductile iron wafer type silent check valve with epoxy powder coating under WRAS approval no. 2008501  
**Model:** 580P-RS  
**Size:** 50mm, 65mm, 80mm, 100mm, 150mm, 200mm



**Body Markings:** CLA-VAL (DN) PN16 DI

**Expiry Date:** 31 August 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)  
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only