



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真 2824 0578
Facsimile

檔號
Reference (8) in WSD 3321/2024 T/J(794/2024)

18 December 2024

Kitz Hong Kong Company Limited
Unit E, 33/F., Monterey Plaza,
15 Chong Yip Street,
Kwun Tong, Kowloon,
Hong Kong

(Attn.: Mr Matthew FUNG)

Dear Sir,

**Approval of “TOYO” Gate Valves
(General Acceptance No. C20240905FS)**

Your letter ref. KHC2024-018 dated 12 August 2024 and subsequent submissions received by this department up to 26 November 2024 refer.

Having considered the test report ref. BC-SUMMARY-2024-122 issued on 25 July 2024 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kitz Corporation
Country of Origin: the Mainland of China
Brand: Toyo
Details of Fitting: Cast iron metal seated gate valve
Model: 501SHK
Size: 65mm, 80mm, 100mm, 125mm, 150mm, 200mm,
250mm, 300mm



Body Markings: (DN size) PN16 CI TOYO
Expiry Date: 15 July 2029
Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only