水 務 署
**Water Supplies Department**

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 *Our ref.* : ( 4 ) in WSD 3321/2024 T/J(793/2024)
來函檔號 *Your ref.* :

電話 *Tel.* :
傳真 *Fax.* : 2824 0578

20 September 2024

Kitz Hong Kong Company Limited
Unit E, 33/F., Montery Plaza,
15 Chong Yip Street,
Kwun Tong, Kowloon,
Hong Kong

(Attn.: Mr Matthew FUNG)

Dear Sir,

**Approval of "TOYO" Strainers**
**(General Acceptance No. C20240647FS)**

Your letters ref. KHC2024-019 and KHC2024-021 dated 13 August 2024 and 28 August 2024 respectively refer.

Having considered the test report ref. BC-SUMMARY-2024-126 issued on 25 July 2024 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

| | |
|---|---|
| **Name of Manufacturer:** | Kitz Corporation |
| **Country of Origin:** | the Mainland of China |
| **Brand:** | Toyo |
| **Details of Fitting:** | Cast iron Y-strainer |
| **Model:** | 381EHK |
| **Size:** | 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm |

香港環境卓越大獎 Hong Kong Awards for Environmental Excellence
10 years+ 同心展關懷 caringorganisation Awarded by The Hong Kong Council of Social Service 香港社會服務聯會頒發

**Body Markings:** TOYO (DN) PN16 CI ➡

**Expiry Date:** 15 July 2029

**Proviso:** The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

(Terry KUNG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue
ME/MC ] - with soft copy only