水 務 署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞 *e-mail* wsdinfo@wsd.gov.hk

電 話 *Telephone*

圖文傳真 *Facsimile* 2824 0578

檔 號 *Reference* (2) in WSD 3321/2025 T/J(793/2025)

22 October 2025

Gate Way Valve & Fitting Ltd.
Flat A1, 4/F, Galaxy Factory Building,
25-27 Luk Hop Street,
San Po Kong, Kowloon,
Hong Kong

(Attn.: Ms Peggy CHEUNG)

Dear Madam,

Approval of "CLA-VAL" Check Valves
(General Acceptance No. ZC20250799)

Your E-Application [file-id: ETJ-GA-20250801-211] dated 1 August 2025 and subsequent submissions received by this department up to 23 September 2025 refer.

Having considered the test report ref. BC-SUMMARY-2025-309 issued on 5 July 2025 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Cla-Val Pacific Ltd
Country of Origin:	New Zealand
Brand:	Cla-Val
Details of Fittings:	Ductile iron wafer type silent check valve with epoxy coating under WRAS approval no. 2104506
Model:	580PS-RS
Size:	50mm, 65mm, 80mm, 100mm, 150mm, 200mm, 250mm
Body Markings:	CLA-VAL (DN) PN16 DI

東江水供港
15 years+ 同心展關懷 caringorganisation

Expiry Date: 21 October 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

(Terry KUNG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only